



Notes:

1. Concrete - 4000 psi 28 day strength.
2. Reinforcement - ASTM A-615 Grade 60 and A-185 WWF.
3. Cement - Type V or Type II with W/C ratio < 0.45.
4. ASTM C-478 governs.
5. Steps shall be non corrosive rubber coated aluminum or nylon and be supplied with the vault.
6. The vault shall be 72" in diameter.

		DATE:
		DRAWING NO.
DRAWN BY: _____	APPROVED BY: CITY ENGINEER _____	